



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
T (786) 315-2590 F (786) 315-2599

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

RC Home Showcase, Inc.  
2970 NW 75<sup>th</sup> Avenue  
Miami, FL 33122

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

### DESCRIPTION: Series "PRO075" Aluminum Project Out Window – L.M.I.

**APPROVAL DOCUMENT:** Drawing No. W14-03, titled "Series PR075 Alum Project Out Wdw. (L.M.I.)", sheets 1 through 12 of 12, dated 02/03/14, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E., bearing the Miami-Dade County Product Control Section Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

### MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 12-1024.06 and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by Manuel Perez, P.E.



*Manuel Perez*  
6/20/14

NOA No. 14-0421.03  
Expiration Date: June 06, 2018  
Approval Date: June 26, 2014  
Page 1

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**A. DRAWINGS**

1. Manufacturer's die drawings and sections.
2. Drawing No. **W14-03**, titled "Series PR075 Alum Project Out Wdw. (L.M.I.)", sheets 1 through 12 of 12, dated 02/03/14, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E.

**B. TESTS**

1. Test reports on:
  - 1) Air Infiltration Test, per FBC, TAS 202-94
  - 2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
  - 3) Water Resistance Test, per FBC, TAS 202-94
  - 4) Drop Load Test, per CPCS 16 CFR 1201 (Cat 11)
  - 5) Large Missile Impact Test per FBC, TAS 201-94
  - 6) Cyclic Wind Pressure Loading per FBC, TAS 203-94
  - 7) Forced Entry Test, per FBC 2411.3.2.1, and TAS 202-94along with marked-up drawings and installation diagram of a Project out aluminum window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-6605**, dated 04/18/12, signed and sealed by Marlin D. Brinson, P.E.  
*(Submitted under previous NOA# 12-1024.06)*

**C. CALCULATIONS**


3. Anchor verification calculations and structural analysis, complying with **FBC-2010**, dated 02/04/14, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E.
2. Glazing complies with **ASTM E1300-09**

**D. QUALITY ASSURANCE**

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

**E. MATERIAL CERTIFICATIONS**

1. Notice of Acceptance No. **13-0129.27** issued to **E.I. DuPont DeNemours & Co., Inc.** for their "**DuPont Butacite® PVB Interlayer**" dated 04/11/13, expiring on 12/11/16.

  
Manuel Perez, P.E.  
Product Control Examiner  
NOA No. **14-0421.03**  
Expiration Date: June 06, 2018  
Approval Date: June 26, 2014


NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED


**F. STATEMENTS**

1. Statement letter of conformance, complying with **FBC-5<sup>th</sup> Edition (2014)**, dated June 19, 2014, issued by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E.
2. Name changed to **RC HOME SHOWCASE, INC.** as registered in the Florida Department of State, Division of Corporation, Sunbiz document dated 10/11/13.  
*(Submitted under NOA# 13-1112.04)*
3. Asset purchase agreement dated 10/01/13, signed by Mr. Manuel A. Kronfle-Kozhaya, Mr. Henry F. Kronfle-Kozhaya, Mr. Raul Casares, Mr. Eusebio Paredes and Ms. Nancy Vias.  
*(Submitted under NOA# 13-1112.04)*
4. Statement letter of complying with the Sales of Assets issued by RC Aluminum Industries, Inc., dated 10/30/13, signed by Raul Casares, President.  
*(Submitted under NOA# 13-1112.04)*
5. Department of State Certification of **RC HOME SHOWCASE, INC.** as a for profit corporation, active and organized under the laws of the State of Florida, dated 10/11/13 and signed by T. Carter, the Secretary of State.  
*(Submitted under NOA# 13-1112.04)*
6. Department of State Certification of **MANUHEN ENTERPRISES, LLC** as a limited liability company, active and organized under the laws of the State of Florida, dated 08/22/13 and signed by N. Culligan, the Secretary of State.  
*(Submitted under NOA# 13-1112.04)*
7. Laboratory compliance letter for Test Report No. **FTL-6605**, issued by Fenestration Testing Laboratory, Inc., dated 04/18/12, signed and sealed by Marlin D. Brinson, P.E.  
*(Submitted under previous NOA# 12-1024.06)*
8. Proposal issued by Product Control Section, dated 09/30/11, with revision, dated 12/19/11, signed by Jaime D. Gascon, P.E.  
*(Submitted under previous NOA# 12-1024.06)*


**G. OTHERS**

1. Notice of Acceptance No. **12-1024.06**, issued to R. C. Aluminum Industries, Inc. for their Series "PRO075" Aluminum Project Out Window – L.M.I., approved on 06/06/13 and expiring on 06/06/18.

  
Manuel Perez, P.E.  
Product Control Examiner  
NOA No. 14-0421.03  
Expiration Date: June 06, 2018  
Approval Date: June 26, 2014




LANDSCAPE FRAMES




PORTRAIT FRAMES

**TYPICAL ELEVATIONS**

ANCHORS DIRECTLY THRU FRAME



LANDSCAPE FRAMES



PORTRAIT FRAMES

**TYPICAL ELEVATIONS**

ANCHORS THRU FRAME ADAPTERS

**SERIES PR075 ALUMINUM PROJECT OUT WINDOW**

DESIGN LOAD RATING FOR THESE WINDOWS TO BE AS PER CHARTS SHOWN ON SHEET 2.

APPROVAL APPLIES TO SINGLE UNITS OR SIDE BY SIDE COMBINATIONS OF P.O./P.O. OR PROJECT OUT WITH OTHER MIAMI-DADE COUNTY APPR'D WINDOWS USING MIAMI-DADE COUNTY APPROVED MULLIONS IN BETWEEN. LOWER DESIGN PRESSURE FROM WINDOWS OR MULLION APPROVAL WILL APPLY TO ENTIRE SYSTEM.

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).

WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.

ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS, ANCHOR EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

ANCHORING OR LOADING CONDITIONS NOT SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.

A LOAD DURATION INCREASE IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY.

ALL SHIMS TO BE HIGH IMPACT, NON-METALLIC AND NON-COMPRESSIBLE.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE FLORIDA BLDG. CODE SECTION 2003.8.4.

THESE WINDOWS ARE RATED FOR LARGE & SMALL MISSILE IMPACT. SHUTTERS ARE NOT REQUIRED.

Engr: JAVAD AHMAD  
CIVIL  
FLA. PE # 70592  
C.A.N. 3538

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 14-042103  
Expiration Date June 6, 2018  
By: [Signature]  
Miami Dade Product Control




**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL. (305) 264-8100 FAX. (305) 262-6978  
COMP-ANL\W14-03RC

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)  
**RC HOME SHOWCASE, INC.**  
2970 N.W. 75TH AVENUE  
MIAMI, FL. 33122  
TEL. (305) 392-6214 FAX. (786) 464-1582

Revisions:		by description	
no	date		

date: 02-03-14  
scale: 1/2"=1'-0"  
dr. by: HAMID  
chk. by:  
drawing no.  
**W14-03**  
sheet 1 of 12





WOOD BUCKS AND METAL STRUCTURE NOT BY RC HOME SHOWCASE  
MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM  
AND TRANSFER THEM TO THE BUILDING STRUCTURE.

**TYPICAL ANCHORS:** SEE ELEV. FOR SPACING  
**1/4" DIA. ULTRACON BY 'ELCO'** ( $F_u=177$  KSI,  $F_y=155$  KSI)  
**1/4" DIA. HILTI KWIK-CON II** ( $F_u=163$  KSI,  $F_y=157$  KSI)  
 INTO 2BY WOOD BUCKS OR WOOD STRUCTURES  
 1-1/2" MIN. PENETRATION INTO WOOD  
 THRU 1BY BUCKS INTO CONC. OR MASONRY  
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY  
 DIRECTLY INTO CONC. OR MASONRY  
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY  
**1/4" DIA. SELF DRILLING SCREWS** (GRADE 5 CRS)  
 INTO MIAMI-DADE COUNTY APPROVED MULLIONS (MIN. THK. = .090")  
 INTO METAL STRUCTURES  
 STEEL : 1/8" THK. MIN. ( $F_y = 36$  KSI MIN.)  
 ALUMINUM : 1/8" THK. MIN. (6063-T5 MIN.)  
 (STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED)

**ANCHOR EDGE DISTANCES**  
 INTO CONCRETE AND MASONRY = 1-1/2" MIN.  
 INTO WOOD STRUCTURE = 5/8" MIN.  
 INTO METAL STRUCTURE = 3/4" MIN.

CONCRETE AT HEAD, SILL OR JAMBS  $f'_c = 3000$  PSI MIN.  
 C-90 HOLLOW/FILLED BLOCK AT JAMBS  $f'_m = 2000$  PSI MIN.

**SEALANTS:**  
 ALL FRAME AND VENT CORNERS SEALED WITH SILICONE.

Engr: JAVAD AHMAD  
 CML  
 FLA. PE # 70592  
 C.A.N. 3538

PRODUCT REVISED  
 as complying with the Florida  
 Building Code  
 Acceptance No. 14-042103  
 Expiration Date June 16, 2018  
 By *Manuel Perez*  
 Miami Dade Product Control

**AL-FAROOQ CORPORATION**  
 ENGINEERS & PRODUCT DEVELOPMENT  
 1235 S.W. 87 AVE  
 MIAMI, FLORIDA 33174  
 TEL (305) 264-8100 FAX (305) 262-6978

COMP-ANL\W14-03RC

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)

**RC HOME SHOWCASE, INC.**  
 2970 N.W. 75TH AVENUE  
 MIAMI, FL. 33122  
 TEL. (305) 392-6214 FAX. (786) 464-1582

revisions:		by description	
no	date		

date: 02-03-14





scale: 1/2" = 1"

dr. by: HAMID

chk. by:

drawing no.  
**W14-03**

sheet 3 of 12



Engr: JAVAD AHMAD  
 CIVIL  
 FLA. PE # 70592  
 C.A.N. 3538

FEB 28 2014

PRODUCT REVISED  
 as complying with the Florida  
 Building Code  
 Acceptance No 14-0421-03  
 Expiration Date June 15, 2018  
 By *Manuel Torres*  
 Miami Dade Product Control

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)  
**RC HOME SHOWCASE, INC.**  
 2970 N.W. 75TH AVENUE  
 MIAMI, FL. 33122  
 TEL. (305) 392-6214 FAX. (786) 464-1582




**AL-FAROOQ CORPORATION**  
 ENGINEERS & PRODUCT DEVELOPMENT  
 1235 S.W. 87 AVE  
 MIAMI, FLORIDA 33174  
 TEL. (305) 264-8100 FAX. (305) 262-6978

COMP-ANL\W14-03RC

Revisions:		
no	date	by description

date: 02-03-14	scale: 1/2" = 1"	dr. by: HAMID	chk. by:
----------------	------------------	---------------	----------

drawing no.  
**W14-03**




WOOD BUCKS AND METAL STRUCTURE NOT BY RC HOME SHOWCASE MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.

**TYPICAL ANCHORS:** SEE ELEV. FOR SPACING  
**1/4" DIA. ULTRACON BY 'ELCO'** (Fu=177 KSI, Fy=155 KSI)  
**1/4" DIA. HILTI KWIK-CON II** (Fu=163 KSI, Fy=157 KSI)  
 INTO 2BY WOOD BUCKS OR WOOD STRUCTURES  
 1-1/2" MIN. PENETRATION INTO WOOD  
 THRU 1BY BUCKS INTO CONC. OR MASONRY  
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY  
 DIRECTLY INTO CONC. OR MASONRY  
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY  
**1/4" DIA. SELF DRILLING SCREWS** (GRADE 5 CRS)  
 INTO MIAMI-DADE COUNTY APPROVED MULLIONS (MIN. THK. = .090")  
 INTO METAL STRUCTURES  
 STEEL : 1/8" THK. MIN. (Fy = 36 KSI MIN.)  
 ALUMINUM : 1/8" THK. MIN. (6063-T5 MIN.)  
 (STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED)

**ANCHOR EDGE DISTANCES**  
 INTO CONCRETE AND MASONRY = 1-1/2" MIN.  
 INTO WOOD STRUCTURE = 5/8" MIN.  
 INTO METAL STRUCTURE = 3/4" MIN.

CONCRETE AT HEAD, SILL OR JAMBS f'c = 3000 PSI MIN.  
 C-90 HOLLOW/FILLED BLOCK AT JAMBS f'm = 2000 PSI MIN.

**SEALANTS:**  
 ALL FRAME AND VENT CORNERS SEALED WITH SILICONE.



Engr: JAVAD AHMAD  
 CML  
 FLA. PE # 70592  
 C.A.N. 3538

PRODUCT REVISED  
 as complying with the Florida  
 Building Code  
 Acceptance No. 14-042103  
 Expiration Date June 6, 2018  
 By *Manuel Ferraz*  
 Miami Dade Product Control

**AL-FAROOQ CORPORATION**  
 ENGINEERS & PRODUCT DEVELOPMENT  
 1235 S.W. 87 AVE  
 MIAMI, FLORIDA 33174  
 TEL. (305) 262-8100 FAX. (305) 262-6978

COMP-ANL W14-03RC

---

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)

**RC HOME SHOWCASE, INC.**  
 2970 N.W. 75TH AVENUE  
 MIAMI, FL. 33122  
 TEL. (305) 392-6214 FAX. (786) 464-1582

revisions:




no	date	by	description

---

date: 02-03-14  
 scale: 1/2" = 1"  
 dr. by: HAMID  
 chk. by:

drawing no.  
**W14-03**  
 sheet 5 of 12





Engr: JAVAD AHMAD  
 CIVIL  
 FLA. PE # 70592  
 C.A.N. 3538

ED 28/04

PRODUCT REVISED  
 as complying with the Florida  
 Building Code  
 Acceptance No 14-042103  
 Expiration Date June 6, 2018

By *Mamook*  
 Miami Dade Product Control

**af c**  
**AL-FAROOQ CORPORATION**  
 ENGINEERS & PRODUCT DEVELOPMENT  
 1235 S.W. 87 AVE  
 MIAMI, FLORIDA 33174  
 TEL (305) 264-8100 FAX (305) 262-6978  
 COMP-ANL\W14-03RC

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)  
**RC HOME SHOWCASE, INC.**  
 2970 N.W. 75TH AVENUE  
 MIAMI, FL. 33122  
 TEL (305) 392-6214 FAX (786) 464-1582






revisions:		by description	
no	date	no	date

date: 02-03-14	scale: 1/2" = 1"	dr. by: HAMID	chk. by:

drawing no.	
W14-03	
sheet 6 of 12	



Engr: JAVAD AHMAD  
CIVIL  
FLA. PE # 70592  
C.A.N. 3538

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 14-0421-03  
Expiration Date June 14, 2018  
By *Manuel Perez*  
Miami Dade Product Control

**af c**

**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL (305) 264-8100 FAX (305) 262-6978  
COMP-ANL\W14-03RC

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)





**RC HOME SHOWCASE, INC.**  
2970 N.W. 75TH AVENUE  
MIAMI, FL. 33122  
TEL (305) 392-6214 FAX (786) 464-1582

revisions:	
no	date by description

date: 02-03-14	scale: 1/2" = 1"	dr. by: HAMID	chk. by:
----------------	------------------	---------------	----------

drawing no.  
**W14-03**

sheet 7 of 12



Engr: JAVAD AHMAD  
CIVIL  
FLA. PE # 70592  
C.A.N. 3538

14-0421.03

14-0421.03

14-0421.03






PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 14-0421.03  
Expiration Date 14-0421.03

By *Manuel*  
Miami Dade Product Control

**af c**  
**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL (305) 264-8100 FAX (305) 262-6978  
COMP-ANL W14-03RC

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)  
**RC HOME SHOWCASE, INC.**  
2970 N.W. 75TH AVENUE  
MIAMI, FL. 33122  
TEL. (305) 392-6214 FAX. (786) 464-1582

revisions:		no date by description	
date:	02-03-14	scale:	1/2" = 1"
dr. by:	HAMID	chk. by:	
drawing no.	W14-03		
sheet	8 of 12		



Engr: JAVAD AHMAD  
 CIVIL  
 FLA. PE # 70592  
 C.A.N. 3538

PRODUCT REVISED  
 as complying with the Florida  
 Building Code  
 Acceptance No. 14-0421-03  
 Expiration Date June 6, 2018  
 By *Manuel*  
 Miami Dade Product Control

**AL-FAROOQ CORPORATION**  
 ENGINEERS & PRODUCT DEVELOPMENT  
 1235 S.W. 87 AVE  
 MIAMI, FLORIDA 33174  
 TEL. (305) 264-8100 FAX. (305) 262-6978

**afC**

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)




**RC HOME SHOWCASE, INC.**  
 2970 N.W. 75TH AVENUE  
 MIAMI, FL. 33122  
 TEL. (305) 392-6214 FAX. (786) 464-1582

COMP-ANL\W14-03RC

Revisions:	
no	date by description


date: 02-03-14  
 scale: 1/2" = 1"  
 dr. by: HAMID  
 chk. by:

drawing no.  
**W14-03**  
 sheet 9 of 12



Engr: JAVAD AHMAD  
CIVIL  
FLA. PE # 70592  
C.A.N. 3538

PRODUCT REVISED  
to comply with the Florida  
Building Code  
Acceptance No. 14-0421-03  
Expiration Date June 6, 2018  
By *Manuel Perez*  
Miami Dade Product Control



**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL (305) 264-8100 FAX (305) 262-6978  
COMP-ANL\W14-03RC

---

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)

**RC HOME SHOWCASE, INC.**  
2970 N.W. 75TH AVENUE  
MIAMI, FL. 33122  
TEL (305) 392-6214 FAX (786) 464-1582

---

revisions:	
no	date by description

---

date: 02-03-14	scale: 1/2" = 1"	dr. by: HAMID	chk. by:
----------------	------------------	---------------	----------

---

drawing no.	no.
W14-03	
sheet 10 of 12	

#### LOCKS:

SURFACE MOUNT METALLIC 10 POINT LOCK SYSTEM  
WITH ACTIVATING LEVER TYPE HANDLE AT MIDPOINT OF FRAME SILL  
FASTENED WITH (4) #10-24 X 3/4" OH MS

SURFACE MOUNT KEEPERS FACING LOCKING POINTS  
FASTENED WITH

- (1) #8 X 3/4" FH SELF DRILLING SCREW
- (1) #12-28 X 1/4" OH THREAD CUTTING MS WITH NUT
- (6) KEEPERS AT FRAME SILL AND (2) KEEPERS AT EACH JAMB FOR LANDSCAPE FRAMES
- (2) KEEPERS AT FRAME SILL AND (4) KEEPERS AT EACH JAMB FOR PORTRATE FRAMES

#### HINGES:

SURFACE MOUNT METALLIC FOUR BAR HINGES  
FASTENED TO FRAME WITH (2) #10-32 X 3/4" PH MS  
FASTENED TO VENT WITH (2) #10-32 X 3/4" PH MS  
LOCATED AT  
27-1/4" FROM BOTTOM FOR LANDSCAPE FRAMES  
44-1/2" FROM BOTTOM FOR PORTRATE FRAMES

#### SNUBBERS:

- (6) SURFACE MOUNT PLASTIC ANTI BLOW OUT CLIPS AT FRAME HEAD AND VENT TOP RAIL
- FASTENED TO FRAME AND VENT WITH (2) #6 X 3/8" PH SMS
- LOCATED AT  
4" FROM EACH END FOR LANDSCPE FRAMES  
7-1/4" FROM EACH END FOR PORTRATE FRAMES  
AND AT MIDSPAN

ITEM	PART #	QUANTITY	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
E1	CM075-001	4	FRAME HEAD/ SILL/ JAMBS 3709 FISA	6063-T6	-
E2	CM075-002	4	VENT HEAD/ SILL/ JAMBS 3707 FISA	6063-T6	-
E3	CM075-007	AS REQD.	FRAME & VENT CORNER LOCK MALE 3550 FISA	6063-T6	-
E4	CM075-004	AS REQD.	FRAME & VENT CORNER LOCK 3551 FISA	6063-T6	-
E5	CM075-005	AS REQD.	FRAME & VENT CORNER LOCK ADAPTOR 1338	6063-T6	-
E6	CM075-006	AS REQD.	LOCK PLATE 3771 FISA	ALUMINUM	-
E7	FX075-003	4	GLAZING BEAD	6063-T6	-
E8	FX075-001	AS REQD.	INSTALLATION FRAME ADAPTER, 6" LONG	6063-T6	-
E9	500Y-010	AS REQD.	SNAP COVER	6063-T6	-
V1	V-101	AS REQD.	SQUARE VINYL TPE MELTPOINT, DUROMETER 70±5	TPE	MELTPOINT
V2	V-108	AS REQD.	TEAR VINYL INSIDE VENT, DUROMETER 65±5	EPDM	TREMCO
V3	V-060A	AS REQD.	FINGER GASKET	NEOPRENE	TREMCO
V4	V-104	AS REQD.	FRAME FLAPPY VINYL PART-C040621, DUROMETER 65±5	EPDM	TREMCO
M1	DOW- 791	AS REQD.	WHITE SILICONE FOR ASSEMBLY	-	-
M2	DOW- 791	AS REQD.	BLACK SILICONE FOR GLAZING	-	-
M3	12206	AS REQD.	SNUBBERS	-	-
M4		2/ LITE	1/4" X 1/2" X 4" LONG T.P.E. SETTING BLOCK	EPDM	DUROMETER 75±5 SHORE A
S1		2/ SNUBBER	#6 X 1/2" LG. FH. SMS.	ST/ST	-
S2		8/ HINGE	#10 X 1/2" LG. PH. THREAD CUTTING POINT "F"	ST/ST	AT 4 BAR HINGES
S3		-	#10-32 X 1/2" LG. FH. THREAD CUTTING MACHINE SCREWS	ST/ST	-
S4		2/ CLIP	#10 X 3/4" PH SMS	ST/ST	-
H1	CR0115-7D	AS REQD.	HANDLE EXTERIOR COLOR WHITE	-	-
H2	KT0006	AS REQD.	LOCK POINT NON CENTER	-	-
H3	851-117-8046	AS REQD.	16" OR 26" 4-BAR HINGE	-	-
H4	05100E03	AS REQD.	FORWARDING SQUARE W/ MUSHROOM HEAD	-	-
H5	-	AS REQD.	MULTI-POINT CONNECTION BARS	-	-

Engr: JAVAD AHMAD  
CIVIL  
FLA. PE # 70592  
C.A.N. 3538

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 14-0421-03  
Expiration Date June 6, 2018  
By *Manuel Ferraz*  
Miami Dade Product Control

**afc**


**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL. (305) 264-8100 FAX. (305) 262-6978

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)


**RC HOME SHOWCASE, INC.**  
2970 N.W. 75TH AVENUE  
MIAMI, FL. 33122  
TEL. (305) 392-6214 FAX. (786) 464-1582

revisions:		no date by description	
date:	02-03-14	scale:	1/2" = 1"
dr. by:	HAMID	chk. by:	


drawing no.  
**W14-03**  
sheet 11 of 12




(E1) FRAME HEAD/SILL/JAMB




(E2) VENT HEAD/SILL/JAMB




(E7) GLAZING BEAD




(E5) CORNER LOCK ADAPTER




(E4) CORNER LOCK




(E8) INSTALLATION FRAME ADAPTER




(E9) SNAP COVER



(E3) CORNER LOCK MALE



VENT CORNERS



FRAME CORNERS

Engr. JAVAD AHMAD  
C.M.I.  
FLA. PE # 70592  
C.A.N. 3538  
FEB 20 2018

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 14-0421.03  
Expiration Date June 6, 2018  
By *Manuel Frey*  
Miami Dade Product Control

**af c**

**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL. (305) 264-8100 FAX. (305) 262-6978

SERIES PR075 ALUM PROJECT OUT WDW. (L.M.I.)

**RC HOME SHOWCASE, INC.**  
2970 N.W. 75TH AVENUE  
MIAMI, FL. 33122  
TEL. (305) 392-6214 FAX. (786) 464-1582

revisions:		no		date		by		description	

date: 02-03-14

scale: 1/2" = 1"

dr. by: HAMID

chk. by:

drawing no.  
**W14-03**

sheet 12 of 12